



14 E Irongate Drive
Waldorf, Maryland 20602

301.645.2798...phone
301.705.5734...fax

February 15, 2019

Maryland Department of the Environment
Inspection and Compliance
1800 Washington Blvd.
Baltimore, MD 21230-1708

RE: Boones MHP, NPDES # MD0050903, STATE PERMIT # 11-DP-0191

The calculation performed on loading of TSS for the week including January 15, 2019 and the week including January 22, 2019 revealed the plant violated the weekly average permit limit for TSS. The permitted weekly average limit for TSS is 8.0 mg/l. The calculated discharge of TSS on 1/15/19 was 9.5 mg/l and for 1/22/19 was 8.8 mg/l.

As a result of these 2 high weekly average results, the monthly average permit limit of 5.3 mg/l for TSS was also violated. The actual calculated monthly average for TSS in January 2019 was 5.4 mg/l.

Although the permit limit for concentration was met for both weeks, the flow through the plant was greater than the .08 MGD the limits are based on.

The owners of Boones MHP are currently developing a wastewater capacity management plan. This plan includes I&I mitigation.

If you have any further questions or concerns regarding this matter please feel free to call.

Regards,

Ed Crooks
410-353-0383